

Disclaimer



All data provided on the following slides is for information purposes only, explicitly non-binding and subject to changes without further notice.



IMO Tier III NOx technology status for large two stroke engines

Mikkel Preem

Emission Technology

R&D, BU-L, CPH



Agenda:

- **The challenge: Emission regulation**
- **Expected demand for Tier III technology**
- **Economy**
- **SCR Installation**
- **EGR Installation**




The challenge: Emission regulation



IMO Regulations




NO_x:



SO_x:

IMO & CARB Fuel-Sulfur Content Limits





Emission remedies to be in compliance with IMO NOx rules



Tier II (2011): Same basis design for Tier II as for Tier I engines!

Tier III (2016): Two roads are followed for reduced NOx emission:



EGR (Exhaust Gas Recirculation)

SCR (Selective Catalytic Reactor)


Both equal applicable!



er III technology Schedules



Low speed





Expected demand for Tier III technology



Emission areas

Emission restricted areas by IMO – ECAs in 2011



Operation analysis based on AIS data





Total fleet with low speed engines is approximately 20000 ships

Distribution in ECA 2007-2008.→

Net flux of new 2144 ships the first years

Ships entering ECA zones in 07,08 and 08+09




Source: IMO Study on Greenhouse Gas Emissions from Ships, MEPC 45(8), 2000.

Need for Tier III technology (estimate)



Ships not in ECA during its lifetime



Estimated Ships mobility: Ship passing into the ECA area over a 20 year period.

Conclusion:

After 20 years at ~88% of the fleet has entered the present ECA zones

Investment in Tier III technology will ensure global mobility.



Economy







Cost parameters Tier III




Operation?

Common	EGR	SCR
HFO Price	NaOH price	Urea price
	NaOH bunker	Urea bunker
	Sludge handle	SCR element


1st cost?



Routing?



Load profiles?



Bunkering?



Retrofit?






EGR and SCR comparison

First cost



EGR/SCR first cost

Hardware + Installation






EGR and SCR comparison

Operation cost



EGR/SCR cost
SCR: High or low grade Urea quality






SCR Installation





SCR Tier III



May 2011: First Tier III compliant two stroke engine!



Tier III achievement 6S46MC-C with SCR




SCR reactor

Vaporizer & mixer unit

Control panel for
reductant injection
and soot-blow

Air compressor &
air tanks



Urea solution tanks


Urea supply unit



The Tier III SCR system High pressure SCR



- Challenge to ensure the right temperatures for SCR





Tier III achievement Results



Tier III is achieved with high pressure SCR

- Sufficient temperature for HFO operation
- Also, at low load with Cylinder & SCR Bypass Valve support



6S46MC-C	25 % load	50 % load	75 % load	100 %load	Cycle
Tier I	18.1	17.2	14.7	12.4	15.8
Tier III	2.9	3.1	2.9	2.5	2.8

The high pressure Tier III SCR system ensures **high fuel flexibility** and **low catalyst volume**



'Rule of thumb' estimates of consumables for SCR.




SFOC:

- **2-3 g/kWh** at low loads.
- **0 g/kwh** when the engine load is sufficient to ensure proper exhaust gas temperature.

Urea consumption (40% aqueous urea solution) depends on the engine setup:

- Tier I engine: approximately **22 g urea/kWh**.
- Tier II engine: approximately **18 g urea/kWh**.

Electrical Power capacity: 6 kW/MW






'Rule of thumb' estimates of space & power requirements for SCR



Installations (+/-15%):

- **Catalyst housing:** 2 m³/MW.
- **Urea/exhaust gas mixing unit:** 0.5 m³/MW
- **Piping** interfaces from ME to Engine Room
- **Urea tank capacity:** about 10% of the fuel oil tank capacity, in case of 100% ECA operation and same bunker period for fuel and urea.



Example 7S50MC-C (10MW):

Catalyst house 20m³, urea mixer 5m³ + pipes, urea tank 100m³, power 60kW.




EGR Installation






AFT mounted integrated EGR unit






EGR variants to cover 4-90MW




1 by 1 configuration
4-46MW



1 by 2 configuration
46-69MW


Single T/C EGR configuration???



2 by 2 configuration
69-90MW




EGR water treatment system






Integrated solution





Engine room installation





'Rule of thumb' estimates of consumables for EGR.




Specific SFOC:

- 1-2g/kWh at all loads.

Specific NaOH consumption :

$$\bullet \text{Volume}_{[m^3/h]} = 2 \text{ liter/MWh/\%S} * \text{fuel-sulphur}_{[\%]} * P_{[MW]} * P_{\text{mean}}_{[\%]}$$

based on 50% aqueous sodium hydroxide solution






'Rule of thumb' estimates of consumables for EGR.



Engine EGR Outline:

- Integrated EGR: only minor change to outline
- Standalone EGR:



$$\text{Volume}_{[m^3]} = P_{[MW]} * (1.8_{[m^3/MW]} + 61_{[m^3/(MW*S\%)]} * \text{fuel-sulphur}_{[\%]})$$

$$\text{Area}_{[m^2]} = \text{Volume}_{[m^3]} / 3.5_{[m]}$$





'Rule of thumb' estimates of consumables for EGR.




EGR Power:

$$\text{Power}_{[\text{kW}]} = 13_{[\text{kW/MW}]} * P_{[\text{MW}]}$$

EGR cooling water:

$$\text{Volume}_{[\text{m}^3/\text{h}]} = 5_{[\text{m}^3/\text{h/MW}]} * P_{[\text{MW}]}$$

In addition to the normal cooling capacity






'Rule of thumb' estimates of space & power requirements for EGR



Water Treatment System outline:

$$\text{Area}_{[m^2]} = 32_{[m^2/(MW*\%S)]} * \text{fuel-sulphur}_{[\%]} * P_{[MW]}$$

$$\text{Power}_{[kW]} = 290_{[kW/(MW*\%S)]} * \text{fuel-sulphur}_{[\%]} * P_{[MW]}$$





'Rule of thumb' estimates of space & power requirements for EGR




• NaOH tank capacity:

$$\begin{aligned} \text{Volume}_{[m^3]} &= 282_{[m^3/MW/\%/ \% / S\%/mdr/\%]} \\ & * P_{[MW]} * P_{\text{mean}}_{[\%]} \\ & * \text{OperationTimeYear}_{[\%]} \\ & * \text{fuel-sulphur}_{[\%]} \\ & * \text{BunkerPeriod}_{[mdr]} \\ & * \text{ECATime}_{[\%]} \end{aligned}$$

• EGR sludge capacity:

$$\begin{aligned} \text{Volume}_{[m^3]} &= 329_{[m^3/MW/\%/ \% / S\%/mdr/\%]} \\ & * P_{[MW]} * P_{\text{mean}}_{[\%]} \\ & * \text{OperationTimeYear}_{[\%]} \\ & * \text{fuel-sulphur}_{[\%]} \\ & * \text{BunkerPeriod}_{[mdr]} \\ & * \text{ECATime}_{[\%]} \end{aligned}$$





EGR Example



Input:

Engine Type	7S70ME-Cunit	
100% SMCR	23	MW
Operation Time per year	68	%
Average load of MCR	75	%
Sulfur %	3	%of HFO
NaOH bunker period	2,0	mdr
Period between EGR sludge disposal	1,5	mdr
Non ECA, Tier II EGR in %	80	% / year
ECA, Tier III in %	20	% / year

Output:

Scaled EGR unit dimensions for retrofit		
EGR unit volumen	84,5	m3
EGR unit area	24,2	m2

Other components in the engine room		
WTS area	22	m2
WTS power	200	kW
Blower power	300	kW
NaOH tank size (50%solution)	40	m3
EGR Sludge tank size	35	m3
Additional cooling water	123	m3/h

Thank You for Your Attention!



All data provided in this document is non-binding. This data serves informational purposes only and is especially not guaranteed in any way. Depending on the subsequent specific individual projects, the relevant data may be subject to changes and will be assessed and determined individually for each project. This will depend on the particular characteristics of each individual project, especially specific site and operational conditions.